



NOTES:

1. TORQUE TERMINAL STRIP WIRING TO 5 IN-LBS.
2. CONTROL WIRING SHALL BE INSULATED WITH CONDUCTORS RATED 105°C, 300V MINIMUM.
3. 75°C COPPER SUPPLY WIRES ONLY.

THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF ASAHI/AMERICA. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE IS FORBIDDEN WITHOUT WRITTEN CONSENT.		
NAME	DATE	
DR JOHN GLASSFORD	6/18/07	
APPD DAVE HURLEY	6/18/07	
PROD LED LESTER	6/19/07	
WO#/SO#		
FILE ACAD11/S92		

ASAHI/AMERICA

ISO 9001 CERTIFIED
35 GREEN STREET, P.O. BOX 653, MALDEN, MA.



QUATER MASTER - 94
OPTIONS WIRING DIAGRAM

SIZE A	DWG. NO. 297S92	REV C
SCALE NTS	SHEET 1 OF 1	